

# DECLARATION OF PERFORMANCE

## N° 2831-CPR-F2707

1- Unique product-type identification code:

**SyCALL R6847L**

2- Intended uses:

**Type A manual indoor alarm point for fire detection and  
fire alarm systems for buildings**

3- Manufacture:

**Synaps Technology S.r.l.**  
Via Pietraferrata 9/1  
34147 Trieste  
ITALIA

Tel: +39 040 9896000

Fax: +39 040 9896001

Email: [info@synaps.it](mailto:info@synaps.it)

4- VVCP systems:

**System 1**

5- Harmonized standards:

**EN 54-11:2001 + A1:2005**

Notified entity: **Bre Global Ireland, N.B. No. 2831**



## 6- Prestazioni dichiarate:

Essential characteristics	Applicable clause	Result	Harmonized standards
Performance parameters in fire condition	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	PASS	EN 54-11:2001 + A1:2005
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	PASS	
Duration of operational reliability: Resistance to temperature	5.7, 5.9	PASS	
Duration of operational reliability: Shock and vibration resistance	Da 5.14 a 5.17	PASS	
Duration of operational reliability: Resistance to humidity	5.10, 5.12	PASS IP42 (Applicant request)	
Duration of operational reliability: Corrosion resistance	5.11, 5.13	PASS	
Duration of operational reliability: Electrical stability	5.6, 5.18	PASS	

The performance of the product identified above is in conformity with the set of declared performances. This declaration of responsibility is issued, in accordance with regulation (EU) no. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed in the name and on behalf of the manufacturer.

Synaps technology Srl, Trieste -ITALY

Trieste, 01 October 2020

Massimo Defendi  
Managing Director

Signature:

  
SYNAPS TECHNOLOGY SRL  
Via Pietraferrata, 9/1  
34147 - TRIESTE  
Partita IVA: 01046470322

